

ELEMENT	COMPLIES (or NA)	DOES NOT COMPLY
----------------	----------------------------	----------------------------------


ACCESSIBLE TRANSIENT LODGING (Sleeping / Dormitory Rooms)

APPLICABLE	Except as specified below, Accessible Transient Lodging shall comply with this section. In addition, public and common use areas of accessible transient lodging shall comply with all other applicable accessibility sections of this checklist.											
FHA	Note that ALL sleeping units shall comply with the Fair Housing Act. Accessible Units , in addition, shall require special mobility features.											
ACCESSIBLE UNITS	Total number of sleeping units provided: []											
Accessible sleeping units required	Total Units	1-25	26-50	51-75	76-100	101-150	151-200	201-300	301-400	401-500	501-1000	1001 & over
	Accessible Units	1	2	3	4	5	6	7	8	9	2% of total	20 + 1/100 > 1000
(Plus)												
Accessible Units w/ Roll-in Showers			1	1	2	2	3	4	4	4	1% of total	
Number of accessible units required: []												
Number of accessible units provided: [] <input type="checkbox"/> <input type="checkbox"/>												
Number of accessible units with roll-in showers required: []												
Number of accessible units with roll-in showers provided: [] <input type="checkbox"/> <input type="checkbox"/>												

Accessible sleeping units for persons with hearing impairments	Total Units	1-25	26-50	51-75	76-100	101-150	151-200	201-300	301-400	401-500	501-1000	1001 & over
	Accessible Units	1	2	3	4	5	6	7	8	9	2% of total	20 + 1/100 > 1000
Number of accessible units required: []												
Number of accessible units provided: [] <input type="checkbox"/> <input type="checkbox"/>												

ACCESSIBLE UNITS	Accessible Units (shall be dispersed among the various types and sizes provided)	<input type="checkbox"/>	<input type="checkbox"/>
	Sleeping area (36" min. on both sides of the bed)	<input type="checkbox"/>	<input type="checkbox"/>
	Turning area (Clear floor space with 60" diameter unobstructed circle required)	<input type="checkbox"/>	<input type="checkbox"/>
	When provided, all areas of accessible units shall be accessible: (living, dining, one sleeping area, one full bathroom, patios/terraces/balconies, parking/garages)		
When provided, complete the applicable [DOORS; TOILET ROOMS; BATHTUBS AND SHOWERS; KITCHENS] sections of checklist)			

STORAGE	Built in closets, shelves, and drawers shall be accessible. Controls shall be accessible. (see clear floor space, reach range, hardware below)	<input type="checkbox"/>	<input type="checkbox"/>
Clear floor space	<p>(a) forward (b) parallel</p>		
	Reach range (15 – 48" forward reach; 9 – 54" side reach, max. 10" deep)	<input type="checkbox"/>	<input type="checkbox"/>
Reach range			

ELEMENT	COMPLIES (or NA)	DOES NOT COMPLY
<p>Reach range</p> 	<input type="checkbox"/>	<input type="checkbox"/>
<p>Hardware (operable with one hand without tight pinching, twisting, or turning of wrist; max. 5# of force)</p>	<input type="checkbox"/>	<input type="checkbox"/>

DOORS	Complete DOORS section
TOILET FACILITIES	Complete TOILET ROOMS section
BATHING FACILITIES / (ROLL-IN SHOWERS)	Complete BATHTUBS AND SHOWERS section
KITCHENS	Complete KITCHENS section
ALARMS	Complete ALARMS section