

ELEMENT		COMPLIES (or NA)	DOES NOT COMPLY												
ASSEMBLY AREAS (auditoriums, arenas, lecture halls etc.)															
APPLICABLE	All assembly areas shall comply with this section. In addition, public and common use areas of assembly areas shall comply with all other applicable accessibility sections of this checklist.														
ACCESSIBLE SEATING	Total number of fixed seats provided in room: []														
Wheelchair locations required	<table border="1"> <tr> <td>Seating Capacity</td> <td>4-25</td> <td>26-50</td> <td>51-300</td> <td>301-500</td> <td>over 500</td> </tr> <tr> <td>Wheelchair locations</td> <td>1</td> <td>2</td> <td>4</td> <td>6</td> <td>6 + 1/additional 100 seats</td> </tr> </table>			Seating Capacity	4-25	26-50	51-300	301-500	over 500	Wheelchair locations	1	2	4	6	6 + 1/additional 100 seats
Seating Capacity	4-25	26-50	51-300	301-500	over 500										
Wheelchair locations	1	2	4	6	6 + 1/additional 100 seats										
	Number of accessible seating locations required: []														
	Number of accessible seating locations provided: []														
	Aisle seats (1% but not less than 1 shall be aisle seats with no, or folding armrests; locations shall be identified with sign)														
	Accessible route (connecting seating with performing areas, stages, arena floors dressing rooms, locker rooms)														
	Wheelchair locations (integral part of fixed seating plan; distributed throughout space; adjoin aisle as egress route; adjoining companion seat)														
	Size when forward or rear access (33" x 48")														
	Size when side access (33" x 60")														
Seating locations	<p>(a) single space (b) adjacent spaces (a) (b)</p>														
	Surface (level, firm, stable, slip-resistant, low pile carpet)														
	Sight lines (over seated and/or standing spectators) (see figs. below)														
Sight lines															
	Companion seating (shoulder alignment back 36" from front of wheelchair space; floor at same elevation)														
ASSISTIVE LISTENING SYSTEMS	Required if audible communications are integral to the use of such spaces (e.g., concert and lecture halls, theatres, meeting rooms, etc.)														
	Permanently installed assistive listening system required if: (fixed seating and at least 50 people accommodated or audio-amplification system is provided)														
	Other assembly areas require: (permanently installed assistive listening system; or adequate number of electrical outlets to support a portable system)														
	Minimum number of receivers (shall be 4% of total seats but no less than 2)														
	Placement (if system serves individual seats, seats shall be < 50' from stage or playing area and have a complete view)														

ELEMENT		COMPLIES (or NA)	DOES NOT COMPLY
ALARMS	If provided, complete ALARMS section		
ACCESSIBLE ROUTE	If required, complete ACCESSIBLE ROUTE section(s) to determine if accessible seating is linked to the required accessible areas described above		
RAMP	If provided along interior accessible route, complete RAMP section		
ELEVATOR	If provided along interior accessible route, complete ELEVATORS section		
LIFT	If provided along interior accessible route, complete PLATFORM LIFT section		