

ELEMENT		COMPLIES (or NA)	DOES NOT COMPLY
ACCESSIBLE ROUTE - EXTERIOR (from parking or public sidewalk to a main accessible entry or activity area)			
ROUTE	Route width (36" min.)	<input type="checkbox"/>	<input type="checkbox"/>
Route width	Route width at turns (36" min. for 90° turn, 42" min. with 48" at the end if additional turn required within 48")	<input type="checkbox"/>	<input type="checkbox"/>
	Route passing space (intersecting walks, or 5' x 5' spaces required at max. 200' intervals)	<input type="checkbox"/>	<input type="checkbox"/>
	Route slope (1:20 max. running slope; 1:50 max. cross slope)	<input type="checkbox"/>	<input type="checkbox"/>
	Route surface (firm, stable, slip-resistant; no abrupt changes > 1/4")	<input type="checkbox"/>	<input type="checkbox"/>
	Gratings (if provided, 1/2" max opening width, perpendicular to path of travel)	<input type="checkbox"/>	<input type="checkbox"/>
Protruding Objects	Protruding objects (if leading edge 27"-80" AFF, max. 4" projection to path of travel)	<input type="checkbox"/>	<input type="checkbox"/>
	Protruding objects on poles (if leading edge 27"-80" AFF, max. 12" projection to path of travel)	<input type="checkbox"/>	<input type="checkbox"/>
	Headroom (6'-8" min.)	<input type="checkbox"/>	<input type="checkbox"/>
CURB RAMP	If provided along exterior accessible route, complete CURB RAMP section		
RAMP	If provided along exterior accessible route, complete RAMP section		
STAIRS	If provided, complete STAIR section if levels are not connected by ramp, elevator or lift		