

ELEMENT	COMPLIES (or NA)	DOES NOT COMPLY
<b>PLATFORM LIFTS</b>		
WHERE PERMITTED	<p>Platform lifts complying with state and local codes are permitted only under the following conditions:</p> <ol style="list-style-type: none"> <li>To provide an accessible route to a performing area in an assembly occupancy.</li> <li>To comply with wheelchair viewing position line-of-sight and dispersion requirements.</li> <li>To provide access to incidental spaces that house no more than 5 persons.</li> <li>To provide access where existing site constraints or other constraints make use of a ramp or elevator infeasible.</li> </ol> <p>Accessible platform lifts may be used as part of an accessible route</p>	
LIFT	<p>Entrance (unassisted entry, operation, and exit, max. 1-1/4" gap at transition runway) (power-operated doors or gates are preferred) <input type="checkbox"/> <input type="checkbox"/></p> <p>Door clear opening (front 32", side 42" min.) <input type="checkbox"/> <input type="checkbox"/></p> <p>Floor plan size (min. 30" x 48", firm, stable, slip-resistant) <input type="checkbox"/> <input type="checkbox"/></p> <div data-bbox="342 764 1445 1024"> </div> <p>Floor surface (firm, stable, slip-resistant; carpet if provided, 1/2" max. pile, securely attached) <input type="checkbox"/> <input type="checkbox"/></p>	
CONTROLS	<p>Location (15"-48" AFF forward, 9"-54" AFF side reach) <input type="checkbox"/> <input type="checkbox"/></p> <div data-bbox="342 1121 1445 1352"> </div> <p>Control location (min. 30" x 48" clear floor area provided at reach range) <input type="checkbox"/> <input type="checkbox"/></p> <p>Control operation (operable with one hand without tight pinching, twisting, or turning of wrist; max. 5# of force) <input type="checkbox"/> <input type="checkbox"/></p>	