

ELEMENT		COMPLIES (or NA)	DOES NOT COMPLY
PUBLIC TELEPHONES			
APPLICABLE	Accessible public pay phones, public closed circuit or other public phones (one/bank/floor shall be accessible)		
	Volume control (provided on accessible phone + provided on 25% of other phones and include signage)		
REQUIRED	Text telephones (if 4 or more pay phones per site, 1 interior phone shall be a text phone)		
	Text telephone (if pay phones provided at stadium, arena, convention center, or covered mall, 1 interior phone shall be a text phone)		
	Text telephone (if pay phones provided at hospital emergency rm., hospital recovery rm., or hospital waiting rm., 1 interior phone shall be a text phone)		
	Portable text phone (if 3 or more pay phones per bank, 1 shall be equipped with a shelf and outlet for portable phone)		
DIMENSIONS	Clear floor space (30" x 48" for forward or parallel approach)	<input type="checkbox"/>	<input type="checkbox"/>
	Reach range (48" AFF max. forward, 54" max. side)	<input type="checkbox"/>	<input type="checkbox"/>
Clear floor space/ Reach range			
	Reach range over obstruction (20-25" deep obstruction w/ knee space, 44" AFF max. forward reach) (24" deep, 34" high obstruction, 46" AFF max. side reach)	<input type="checkbox"/>	<input type="checkbox"/>
Reach range			
	Protruding objects (if leading edge 27"-80" AFF, max. 4" projection to path of travel)	<input type="checkbox"/>	<input type="checkbox"/>
	Protruding objects on poles (if leading edge 27"-80" AFF, max. 12" projection to path of travel)	<input type="checkbox"/>	<input type="checkbox"/>
Protruding object			
	Hearing aid compatible (hearing aid compatible w/ volume control)	<input type="checkbox"/>	<input type="checkbox"/>
	Controls (pushbutton controls)	<input type="checkbox"/>	<input type="checkbox"/>
	Telephone books (if provided, located within reach ranges)	<input type="checkbox"/>	<input type="checkbox"/>
	Cord length (min. 29" long)	<input type="checkbox"/>	<input type="checkbox"/>
	TTY height (touch surface 34" min. AFF)	<input type="checkbox"/>	<input type="checkbox"/>
	Portable TTY (if required, provide shelf and electrical outlet)	<input type="checkbox"/>	<input type="checkbox"/>
	Volume Control and Text Telephones (shall be identified with international symbol)	<input type="checkbox"/>	<input type="checkbox"/>

ELEMENT

**COMPLIES
(or NA)**

**DOES NOT
COMPLY**

