

| ELEMENT | | COMPLIES (or NA) | DOES NOT COMPLY |
|----------------|---|--------------------------|--------------------------|
| RAMP | | | |
| WHERE REQUIRED | Wherever the slope of an accessible route exceeds 1:20 (5%). The slope of the ramp should be the least possible and comply with the requirements below. | | |
| RAMP | Clear width (36" min.) | <input type="checkbox"/> | <input type="checkbox"/> |
| | Ramp slope (1:12 max. running slope; 1:50 max. cross slope) | <input type="checkbox"/> | <input type="checkbox"/> |
| | Ramp slope alternate (1:10 max. up to 6" high; 1:8 max. up to 3" high) | <input type="checkbox"/> | <input type="checkbox"/> |
| | Ramp surface (firm, stable, slip-resistant; no abrupt changes > 1/4") | <input type="checkbox"/> | <input type="checkbox"/> |
| | Ramp rise (max. 30" rise for any one ramp segment) | <input type="checkbox"/> | <input type="checkbox"/> |
| | Doorways (when located adjacent to ramp, shall have required level maneuvering area at door) | <input type="checkbox"/> | <input type="checkbox"/> |
| | Landings (min. width = to ramp width; 60" min. length; 60" x 60" min. if change in direction) | <input type="checkbox"/> | <input type="checkbox"/> |
| Landings | <p>(a) (b)</p> | | |
| HANDRAILS | Handrails (required if ramp height > 6" or horizontal projection exceeds 72" (unless the ramp is a curb ramp); required on both sides of ramp) | <input type="checkbox"/> | <input type="checkbox"/> |
| | Handrail height (34"-38" AFF, w/ 12" extensions beyond top and bottom parallel to ground) | <input type="checkbox"/> | <input type="checkbox"/> |
| | Handrail (1 1/4" – 2" diameter or equivalent gripping surface w/ 1-1/2" space between handrail and wall) | <input type="checkbox"/> | <input type="checkbox"/> |
| Diameter | <p>(a) circular (b) non-circular (c) non-circular</p> | | |
| | Handrail (shall be uninterrupted, ends rounded or returned smoothly to floor, wall or post and not rotate in their fittings) | <input type="checkbox"/> | <input type="checkbox"/> |
| | Edge protection provided (walls, railings, surface extension, or min. 2" high curbs at drop-offs) | <input type="checkbox"/> | <input type="checkbox"/> |
| | Outdoor ramp (ramp and approach designed so water will not accumulate) | <input type="checkbox"/> | <input type="checkbox"/> |
| Dimensions | <p>(a) ramps (b) extended surface (c) curb or barrier</p> | | |