




ELEMENT		COMPLIES (or NA)	DOES NOT COMPLY
STAIRS			
APPLICABLE	Interior and exterior stairs connecting levels not served by an elevator, ramp, or other means of vertical access shall comply with this section.		
STAIRS	Risers (uniform height; 4" – 7" high; no open risers)	<input type="checkbox"/>	<input type="checkbox"/>
	Treads (uniform depth; min. 11" deep)	<input type="checkbox"/>	<input type="checkbox"/>
	Nosings (see figs. below)	<input type="checkbox"/>	<input type="checkbox"/>
			
	Detectable warnings ([IAC requirement] require at top of stair run except for – stairs in dwelling units, enclosed stair towers, or stairs set to the side of the path of travel)	<input type="checkbox"/>	<input type="checkbox"/>
HANDRAILS	Handrails (required on both sides, continuous switchback on inside handrail, shall not rotate in their fittings)	<input type="checkbox"/>	<input type="checkbox"/>
	Handrail height (34"-38" AFF measured at nosing)	<input type="checkbox"/>	<input type="checkbox"/>
	Extensions (top of run: parallel to floor, 12" min. beyond top of nosing; bottom of run: continued slope for one tread width beyond bottom riser + min. 12" parallel to floor) (see figs. below)	<input type="checkbox"/>	<input type="checkbox"/>
	Extensions for existing conditions (not required if hazardous or impossible due to plan configuration)	<input type="checkbox"/>	<input type="checkbox"/>
	Dimensions		
Diameter	Handrail (1 1/4" – 2" diameter or equivalent gripping surface; w/ 1-1/2" space between handrail and wall; not obstructed at top or sides)	<input type="checkbox"/>	<input type="checkbox"/>
	Handrail (uninterrupted gripping surface, ends rounded or returned smoothly to floor, wall or post) Handrail (shall be continuous, or ends rounded or returned smoothly to floor, wall or post)	<input type="checkbox"/>	<input type="checkbox"/>
	Handrail (1 1/4" – 2" diameter or equivalent gripping surface w/ 1-1/2" space between handrail and wall)	<input type="checkbox"/>	<input type="checkbox"/>
			
	Outdoor stair (stair and approach designed so water will not accumulate)	<input type="checkbox"/>	<input type="checkbox"/>